

---

REPORT TO:	ETWALL JMC	AGENDA ITEM:	9
DATE OF MEETING:	4 <sup>TH</sup> OCTOBER 2004	CATEGORY:	RECOMMENDED
REPORT FROM:	CENTRE MANAGER	OPEN PARAGRAPH NO:	
MEMBERS' CONTACT POINT:	STEVE WRIGHT	DOC:	
SUBJECT:	POOL FILTER	REF:	
WARD(S) AFFECTED:	ETWALL, HATTON, HILTON, NORTH WEST, RETON & WILLINGTON	TERMS OF REFERENCE:	

---

### 1.0 Recommendations

- 1.1 That the swimming pool filter be refurbished this financial year.
- 1.2 That Priority 2 and 3 works be carried out at the same time if the contingency budget is not required for filter refurbishment work.

### 2.0 Purpose of Report

- 2.1 To report back to the JMC on the costs involved in carrying out maintenance work to the swimming pool plant.

### 3.0 Detail

- 3.1 At the last meeting of the JMC it was reported that an ultrasonic condition survey on the pool filter shell had been carried out (see Annexe 'A' to this report).
- 3.2 Although the water quality is satisfactory at the moment members will note that some immediate maintenance works is required now, to be prolong the life of the existing pool.
- 3.3 Two quotations have now been obtained to carry out work to the filtration plant. Priority 1 is the filter itself. Additional work (if any) will only become apparent when the vessel is empty. The pool would have to close for seven to nine day's.
- 3.4 Priority 2 & 3 can be carried out at a later date whilst the pool is opened.

Priority 2 - replace the air blower

Priority 3 - replace the strainer box and valve

#### **4.0 Financial Implications**

4.1	<u>Barr &amp; Wray Ltd</u>	<u>Pool &amp; Spa People</u>
	£	£
<b>Priority 1</b>		
<b>Filter Refurbished</b>	10,155	7,990
<b>(additional work if any)</b>	4,000	
<b>Priority 2</b>		
<b>Air Blower</b>	3,315	5,480
<b>Priority 3</b>		
<b>Strainer Box &amp; Valve</b>	2,659	2,140
<b>Priority 2 &amp; 3 (above)</b>		
<b>One visit</b>	5,597	

#### **5.0 Community Implications**

5.1 The swimming pool will need to be closed for nine day's.

#### **6.0 Conclusions**

6.1 The pool water quality is excellent at this moment in time, however there can be no guarantee how long this may continue. The programmed maintenance work outlined in this report is essential if this pool is to continue to serve education and community use for the foreseeable future.

#### **7.0 Background Papers**

7.1 Condition survey – The Pool and Spa People Ltd

Quotation – The Pool and Spa People Ltd

Quotation – Barr & Wray Ltd